

Format No-RA/01

TEST REPORT ISSUED BY: VASAI LAB

TEST REPORT NO.

TEST REPORT DATE

NAME OF CUSTOMER:

M/s. Elantor Solutions Pvt. Ltd. A/04, Blue Heaven, Opp. IDBI Bank,

Thakur Complex, Kandivali (East) Mumbai – 400101

REFERENCE NO. & DATE

QUANTITY

CONDITION OF SAMPLE ON RECIEPT OF SAMPLE

**TEST METHOD** 

TEST REPORT

SAMPLE TESTED BY / AT : VASAI LAB

: VST-2175-TR-200890

: 11-01-18

PROJECT / SITE ADDRESS:

Elantor Solutions Pvt. Ltd.

A/04, Blue Heaven, Opp. IDBI Bank,

Thakur Complex, Kandivali (East) Mumbai – 400101

: Letter Dated 10/01/2018

: 01 No.

: Satisfactory

: Custom Method

REBAR ANCHOR PULL OUT TEST RESULT

Date of Testing

: 11-01-18

Dia. Of Rebar / Anchor

- 12

Rebar Anchor Fixing Grout Material : NA

Fastener Sr No.	(mm) Specimen ID Mark	Grade of Concrete	Anchor Fastener Penetration Depth (mm)		Ultimate Pull-Out Load (T)	Observed Remark
1	Drill Dia 12mm	M 30	75	31.00	3.2	Anchor fastener Pulled Out from RCC at Ultimate Load

## NOTE:

- -- Sample/s was/were not drawn by laboratory.
- -- The Reported result/s is/are valid only to the sample submitted to the laboratory.
- -- No part of the report, except in full, shall be reproduced without written consent of the laboratory.
- The report is valid only when Global Lab hologram is available on the report.





A. SHARMA Technical Manager

Page 1 of 1