



# GLOBAL LAB

A World of Quality Material Testing

Format No-RA/01

## TEST REPORT

TEST REPORT ISSUED BY : VASAI LAB

SAMPLE TESTED BY / AT : VASAI LAB

TEST REPORT NO.

: VST-3220-TR-219415/01

TEST REPORT DATE

: 05/04/2018

### NAME OF CUSTOMER :

M/s. Elantor Solutions Pvt. Ltd.  
A/04, Blue Heaven, Opp. IDBI Bank,  
Thakur Complex, Kandivali (East) Mumbai – 400101

### PROJECT / SITE ADDRESS :

Transcon Triumph, Transcon Developers Pvt.Ltd.,  
Opp. Pramukh Heights, Near Oberoi Spring, Veera Desai Road,  
(Left Turn from Gundecha Symphony) Andheri West. Mumbai.

REFERENCE NO. & DATE

: Letter Dated 04/04/2018

QUANTITY

: 02 Nos.

CONDITION OF SAMPLE ON RECEIPT OF SAMPLE

: Satisfactory

TEST METHOD

: Custom Method

## ANCHOR BOLT PULL OUT TEST RESULT

Date of Testing : 04/04/2018

| Sr No. | Specimen ID Mark                          | Grade of Concrete | Dia. Of Anchor Bolt (mm) | Anchor Bolt Fixing Grout Material    | Anchor Bolt Penetration Depth (mm) | Max. Pull-Out Load (kN) | Max. Pull-Out Load (Ton) | Observed Remark   |
|--------|-------------------------------------------|-------------------|--------------------------|--------------------------------------|------------------------------------|-------------------------|--------------------------|-------------------|
| 1      | Podium-5 Slab<br>(Drilling Hole 14mm dia) | M 40              | 12                       | Pure Epoxy Chemical Mortar / Mr.Bond | 110                                | 48.4                    | 4.9                      | Anchor Bolt break |
| 2      | Podium-5 Slab                             | M 50              | 12                       | Pure Epoxy Chemical Mortar / Mr.Bond | 110                                | 46.4                    | 4.7                      | Anchor Bolt break |

### NOTE :

- Sample/s was/were not drawn by laboratory.
- The Reported result/s is/are valid only to the sample submitted to the laboratory.
- No part of the report, except in full, shall be reproduced without written consent of the laboratory.
- The report is valid only when Global Lab hologram is available on the report.



Authorized Signatory